

Zakázka číslo :
 Název : MŠ
 Adresa : Děčín Byňov

Výpočtová venkovní teplota : -12 °C
 Charakteristické číslo budovy B : 12

Číslo místnosti	Název místnosti	ti [°C]	Plocha [m ²]	Objem [m ³]	Qp [W]	Qv [W]	Qz [W]	Qc [W]	Qr [W]
1.NP									
101	zádveří	18	2.89	9.7	681	52	0	733	686
102	chodba	20	15.68	52.5	1207	303	0	1510	1215
103	šatna	20	14.96	50.1	1581	290	0	1871	1552
104	herna	22	60.05	201.2	6104	1235	0	7338	6058
105	jídelna	22	23.00	77.0	2141	473	0	2614	2123
106	umývárna	24	10.97	36.7	1074	239	0	1313	1024
107	kuchyň	20	15.74	52.7	876	305	0	1181	885
109	šatna	20	3.74	12.5	231	72	0	303	233
110	chodba	20	8.90	29.8	182	172	0	354	187
Celkem :			155.93	522.4	14077	3141	0	17217	13963
2.NP									
201	herna	22	45.41	137.1	3961	842	0	4803	4803
202	kancelář	20	13.79	41.6	1788	241	0	2029	2029
203	ložnice	22	39.96	120.7	3355	741	0	4096	4096
204	umývárna	24	10.22	30.9	736	201	0	937	937
205	chodba	20	13.89	41.9	1563	242	0	1805	1805
206	wc	20	1.52	4.6	389	27	0	415	415
Celkem :			124.79	376.9	11792	2294	0	14085	14085
Celkem za zakázku :			280.72	899.2	25869	5435	0	31302	28048